

CORRIGENDUM TO E-TENDER NOTICE TE-31

Tender Reference No: CTTC/BBSR/TRG/TBI/21-22/TE-31 and Tender ID: 2021_DC_630363_1 for Industrial Automation and IOT Lab. Bidders are requested to refer the revised technical details uploaded in the website. The bid submission closing date is extended up to 29.06.2021, at 11.00 AM and same shall be opened on 30.06.2021, at 11.00 AM.



Central Tool Room & Training Centre
B-36, Chandka Industrial Area, Bhubaneswar-751024
Phone: (0674) 3011710
Fax: (0674) 3011750/3011710, Email: cttc@cttc.gov.in

L. Rajsekhar
(L. Rajsekhar)
General Manager

CORRIGENDUM No -1

**MSME Technology Centre
Central Tool Room & Training Centre, Bhubaneswar
Technical Specification of Industrial Automation, TE-31, Dated: 18.05.2021
Annexure-II**

	Existing Specification	Revised Specification
Sl No.	Workstation	PLC Workstation
	PLC & RTU	
4.6	<p>Provisions shall meet the following installed-spare requirements:</p> <ol style="list-style-type: none">1. I/O points – 25 percent spare I/O capacity for each type of I/O signal at every PLC and remote I/O location. All spare I/O shall be wired to field terminal blocks.2. PLC backplane – the greater of:<ol style="list-style-type: none">a) 25 percent spare capacity, orb) 3 spare backplane slots.3. PLC memory – 50 percent spare program volatile memory.	<p>Provisions shall meet the following installed-spare requirements:</p> <ol style="list-style-type: none">1. I/O points – 25 percent spare I/O capacity for each type of I/O signal at every PLC and remote I/O location. All spare I/O shall be wired to field terminal blocks. Minimum 16 Digital (I/O) and 4-6 Analogue (I/O)2. PLC backplane – the greater of:<ol style="list-style-type: none">a) 25 percent spare capacity, orb) 3 spare backplane slots.3. PLC memory – 50 percent spare program volatile memory.